



TEST REPORT

DATE: 02-20-2020

Page 1 of 1

TEST NUMBER: 0263934

CLIENT	Verduren
TEST METHOD CONDUCTED	ISO 4918 Resilient, Textile and Laminate Floor Coverings - Castor Chair Test
DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Verduren Top Shield
COLOR	Clear
BACKING	Wood/Polymer
REFERENCE	Verduren

GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded with weight. The chair castors are set to cause a circular cycling motion resulting in a circle shaped wear pattern.

TEST RESULTS

NUMBER OF CYCLES	APPEARANCE RATING
25,000	No delamination or separation. Slight wear to surface in traffic area.



APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.